



## GAS HEATER COMMISSIONING

### Customer Address

Company Name	Kingspan
Address	Kingspan Insulation Ltd, Torvale Industrial Estate, Pembridge, Leominster, Herefordshire, County Of, HR6 9LA
Telephone	01544 388601

### Commissioning Engineer

Engineer's Name	James Greaves
Company Name	Lindon Environmental
Address	7 Glendon Close, Market Drayton, Shropshire, TF9 1NX
Telephone	01630655100
Gas Safe Number	10744
Company Gas Safe Number	10744

### Heater Type

Model	LX
Fuel	Natural Gas

### Heater Details

Serial Number	22F653200/4
Model Number	LX70

### Commissioning Data

Running Current	2.4 amps	
	<b>High Fire</b>	<b>Low Fire</b>
Inlet Pressure	18 mbar	19 mbar
Burner Pressure	9.34 mbar	2.4 mbar
CO	60 ppm	60 ppm
CO2	8.07 %	5.44 %
CO/CO2 Ratio	0.0007	0.0011
O2	6.8 %	11.4 %
Efficiency (Nett)	89 %	88 %
Ambient Temp	29 degC	29 degC
Flue Gas Temp	29 degC	157 degC

### Comments

Date: 2022-10-13